

Incident on July 30, 2015

Worker Entered Cyclotron During Bombardment

WCF personnel, using an out dated SOP, entered the vault during a bombardment to conduct Gamma and Neutron Surveys of the area.

This incident was flagged by the CNSC on July 31, 2015.

There was no effect on the environment or health and safety of the public due to this incident.

Exposure to the worker involved did not approach any occupational dose limits.